




# Air Arrest<sup>®</sup> CB44 6" x 14" Cable Wall Seal

Tate Access Floors, Inc.  
 7510 Montevideo Road  
 Jessup, MD 20794  
 Tel (410) 799-4200  
 Fax (410) 799-4207



(4" x 13" Useable Space)



Cut 14-1/2" X 6" hole through wall and install with screws or contact adhesive

Grommet frame formed of ABS plastic with passage way consisting of intermediate layer of flexible EPDM rubber and interwoven nylon filaments. Air Arrest grommets are not rated for use in a U.L. listed firewall assembly.

## Air Flow Through Grommet

The data in the table was derived from laboratory testing and can be used to estimate the volume of air that will flow through the seal with typical cable bundles passing through the brushes

Cable Volume	Air Flow Through Seal(CFM)	
	0.05' static pressure	0.10' static pressure
No cables	12	19
(60) Cat5e cables	18	27
(60) Cat5e cables+ (7) BX cables	32	47